

BALTIMORE GAS AND ELECTRIC COMPANY (BGE)

Residential HVAC Diagnostic Tune-up (a BGE Smart Energy Savers ProgramSM)

2009 Performance Sheet



This Performance Sheet must be uploaded as a supporting document to the Rebate Application.

I. Contact/Site Information			
Company Name:	Technician Name:		
Service Date:	BGE Account Number:		
Customer Name:	Customer Telephone Number:		
Residence Address:	City:	State:	Zip:

II. Installed Central A/C or Heat Pump Equipment		
Condenser/Outdoor Unit:	Manufacturer:	Tonnage:
	Model Number:	SEER:
	Serial Number:	EER:
	Cooling Capacity (Btuh):	HSPF:
	Heating Capacity (Btuh) @ 47 °F:	
Coil/Indoor Unit:	Manufacturer:	
	Model Number (if available):	Serial Number (if available):

III. Installed Gas Furnace Equipment		
Gas Furnace:	Manufacturer:	AFUE:
	Model Number:	Serial Number:
	Input Btuh:	Output Btuh:
	ECM or ICM: <input type="checkbox"/> Yes <input type="checkbox"/> No	Indicate Type: ECM <input type="checkbox"/> or ICM <input type="checkbox"/>

IV. Gas Meter Test Calculations		
Return air: _____ °F DB	Supply air: _____ °F DB	
Orifice size:	Manifold pressure: _____ IWC	Gas meter dial size:
Gas meter seconds for one revolution of meter:	Low:	High:

V. Gas Combustion Test			
Indicate high fire gas rate (from meter lookup tables):			
Indicate actual high fire rate:			
Indicate temperature rise at high fire rate:			
O2:	CO:	Stack temperature: _____ °F	Draft pressure: _____ PSI

VI. Pre-Test Requirements			
Fan Speed Setting:	<input type="checkbox"/> Low	<input type="checkbox"/> Medium-Low	<input type="checkbox"/> Medium <input type="checkbox"/> Medium-High <input type="checkbox"/> High
Method of Airflow Measurement:	<input type="checkbox"/> Pressure matching method	<input type="checkbox"/> Anemometer	<input type="checkbox"/> Flow grid <input type="checkbox"/> Transverse pitot tubes
	<input type="checkbox"/> TESP Method/Blower Table	<input type="checkbox"/> Temperature rise method (heating only)	

VII. Performance Test Data

Fan Airflow (CFM measured/verified): Before _____ CFM @ _____ IWC After _____ CFM @ _____ IWC		
Test Description	Before	After
System Watts (watts = measured volts x measured amps)	_____ Watts	_____ Watts
Coil Entering DB/WB (coil entering temperatures)	_____ °F _____ °F	_____ °F _____ °F
Coil Leaving DB/WB (coil leaving temperatures)	_____ °F _____ °F	_____ °F _____ °F
Coil Capacity (A) (Btu = CFM x 4.5 x Δ Enthalpy)	_____ Btuh	_____ Btuh
Equipment Nominal Btu (B) (manufacturer's rated nominal Cooling Btuh)	_____ Btuh	_____ Btuh
(A÷B) Equals System Effective Efficiency (should exceed 90% of nominal capacity)	_____ %	_____ %

VIII. Refrigerant Charge Verification/Test Results

Refrigerant Charge (indicate quantity added or recovered)	<input type="checkbox"/> Added <input type="checkbox"/> Recovered	_____ Lb. _____ Oz.
Refrigerant Type	<input type="checkbox"/> R-22 <input type="checkbox"/> R-410A <input type="checkbox"/> Other	
	Before	After
Condenser Entering Air DB (outdoor air temperature at condenser)	_____ °F	_____ °F
Suction Pressure (required to check refrigerant charge)	_____ psi	_____ psi
Discharge Pressure (required to check refrigerant charge)	_____ psi	_____ psi
Suction Line Temperature (required to check refrigerant charge)	_____ °F	_____ °F
Discharge Line Temperature (required to check refrigerant charge)	_____ °F	_____ °F
Actual Results (indicate before and after results)	_____ °F	_____ °F
OEM Specification (indicate required temperatures and charging method)	_____ °F	_____ °F
<input type="checkbox"/> Approach <input type="checkbox"/> Subcooling <input type="checkbox"/> Superheat		

IX. Pre-Test Calculation Worksheet

System Watts (Power)	Volts	x Amps	= Watts
Blower motor			_____ Watts
Compressor/Condenser Fan			_____ Watts
Total System Watts (Add blower motor and compressor/condenser fan watts to get total)			_____ Watts
Converting Wet Bulb (WB) to Enthalpy (<i>measure all temperatures to the 1st decimal place and record Enthalpy to 2 decimal places</i>)			
Entering Coil WB	_____ °F	=	Btu/Lb Enthalpy (A)
Leaving Coil WB	_____ °F	=	Btu/Lb Enthalpy (B)
Coil Capacity CFM	Coil Capacity CFM	x	4.5
		x	4.5
		x	(Enthalpy A minus B)
		=	_____ Btuh
System Efficiency	Coil Capacity (Btuh)	÷	Equipment Nominal Capacity (Btuh)
		÷	= System Effective Efficiency (%)

X. Tune-Up Procedures

Required Procedures	Comments
<input type="checkbox"/> Changed or cleaned air filter	
<input type="checkbox"/> Cleaned condenser coil	
<input type="checkbox"/> Cleaned evaporator coil	
<input type="checkbox"/> Adjusted air flow	
<input type="checkbox"/> Adjusted refrigerant charge	

XI. Post-Test Calculation Worksheet

System Watts (Power)	Volts	x Amps	= Watts				
Blower motor			_____ Watts				
Compressor/Condenser Fan			_____ Watts				
Total System Watts (Add blower motor and compressor/condenser fan watts to get total)			_____ Watts				
Converting Wet Bulb (WB) to Enthalpy (<i>measure all temperatures to the 1st decimal place and record Enthalpy to 2 decimal places</i>)							
Entering Coil WB	_____ °F	=	Btu/Lb Enthalpy (A)				
Leaving Coil WB	_____ °F	=	Btu/Lb Enthalpy (B)				
Coil Capacity CFM	Coil Capacity CFM	x	4.5	x	(Enthalpy A minus B)	=	Btuh
		x	4.5	x		=	_____ Btuh
System Efficiency	Coil Capacity (Btuh)	÷	Equipment Nominal Capacity (Btuh)		=	System Effective Efficiency (%)	
		÷			=		

Notes

If the ductwork is installed in unconditioned space, a difference between the room return air and coil entering air temperatures could indicate delivered capacity loss from duct leakage and/or thermal transmission gains. Duct sealing or insulating may be recommended to improve delivered capacity, comfort and efficiency. **Please indicate the duct location's temperature: _____ °F.**

A difference between the coil leaving temperature and the temperature delivered to a supply register usually indicates thermal transmission gains through inadequate insulation. If the supply air ducts leak, air is lost to the unconditioned space. If return air ducts leak, then unconditioned air at significantly elevated temperatures (i.e., 140 °F vs. 78 °F) is drawn into the system, which results in decreased operational efficiency.

If inadequate airflow cannot be achieved by replacing the filter, cleaning the evaporator coil or changing the blower speed, the problem is likely caused by an inadequate distribution system and repair / renovation may be required.

For additional assistance regarding this form, please contact ResidentialHVAC@BGESmartEnergy.com or call 410.290.1214.

For more information about the program, go to BGESmartEnergy.com